



INVESTIGATION REPORT  
BUILDING AND SAFETY/LAND DEVELOPMENT DIVISION

Location of Problem: 6661 E. Sacramento St.

Locality: Altadena

Description of Problem: Gas leak and  
miscellaneous violation

Requested by: Captain Defina Phone: (818) 797-2109

Address: \_\_\_\_\_

Request call back after investigation? Yes ☒ No ☐

Received by: E. Garcia Date: 1-17-97

Assigned/Referred to: Same Date: 11

Report of Investigation: Reported to the Gas Co.  
Made investigation and Gas Co. was  
there. They found a leak in the  
water heater and turned off gas to  
water heater. They left a citation.  
I sent correction notice to owner  
with various violations.

elg  
1-17-97

Investigator: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_

Copy Sent to: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_

Report Phoned to: \_\_\_\_\_ Title: \_\_\_\_\_ Date: \_\_\_\_\_

JOB  
ADDRESS

1661 E. Sacramento St.

OWNER

Elsa B. Taylor

Based on a referral from the Los Angeles County Fire Dept., an investigation was made on January 17, 1997, by Building and Safety. The following Substandard and possible hazardous conditions were observed.

1. Water heater leaking gas and missing parts
2. Nonpermitted laundry location with dryer exhausting indoors, flex connector in an unapproved location.
3. Cord wiring connections.

1-17-97 E. Garcia

DATE

INSPECTOR'S SIGNATURE

JOB  
ADDRESS

1661 E. Sacramento St.

OWNER

Elsa B. Taylor

4. Missing switch plates throughout.
5. Missing receptacle covers throughout.
6. Nonoperative lav in the bathroom.  
(missing trap).
7. Broken grates on floor furnace alarming for possible damage to appliance and injury to occupants.
8. Holes in walls and a general state of nonmaintenance and disrepair.

A more thorough inspection will need to be

1-17-97 E. Garcia

DATE

INSPECTOR'S SIGNATURE

JOB  
ADDRESS

1661 E. Sacramento St.

OWNER

Elsa B. Taylor

made to determine a more complete list of violations.

Permits are needed for replacement of the water heater and for other repairs. Repairs to commence within 10 days. Licensed contractors only. Water heater to be replaced immediately. Please call me if you have any questions on Monday, Wednesday, or Friday between 8 a.m. - 9 a.m.

1-17-97 E. Garcia

DATE

INSPECTOR'S SIGNATURE

Owner

Elsa B. Taylor  
6515 Napa Avenue  
Alta Loma, CA 91701-3920

Tract 8469  
Lot 6

Built 1929

5839-012-006